

[Unit: mm]

3D View

4 holes for Anchor Bolts (M10)

Labels: 1 (Fan), 2 (Control Panel), 3 (Access Panel), 4 (Drain Connector), 5 (Piping Ports)

Side View
(Piping Connection Ports)

Labels: 1 (Air Outlet), 2 (Power Supply cable Hole), 3 (Power and communication cable Hole), 4 (Gas Pipe Connection), 5 (Liquid Pipe Connection), 6 (SVC Valve (gas)), 7 (SVC Valve (Liquid)), 8 (Handle)

5- ϕ 12, ϕ 20holes for drain connector

Symbols

- Piping Direction
- ▲ Datum line

Note

- Unit should be installed in compliance with the installation manual in the product box.
- Unit should be grounded in accordance with the local regulations or applicable national codes.
- All electrical components and materials to be supplied from the site must comply with the local regulations or international codes.
- Electric characteristics chapter should be considered for electrical work and design. Especially the power cable and circuit breaker should be selected in accordance with that.

8	Handle	-
7	SVC Valve (Liquid)	-
6	SVC Valve (gas)	-
5	Liquid Pipe Connection	Flare joint
4	Gas Pipe Connection	Flare joint
3	Power and communication cable Hole	ODU-IDU connection
2	Power Supply cable Hole	ODU power supply
1	Air Outlet	-
No.	Part Name	Description